EFFICIENCY OF ELECTROCOAGULATION METHOD TO REDUCE COD, BOD AND TSS IN TANNERY INDUSTRY WASTEWATER: APPLICATION OF THE BOX–BEHNKEN DESIGN

Edwar AGUILAR-ASCÓN^{1*}, Liliana MARRUFO-SALDAÑA², Walter NEYRA-ASCÓN¹

¹Universidad de Lima, Instituto de Investigación Científica (IDIC), Av. Javier Prado 4600, Surco, Lima, Perú; e-mails: eaguilaa@ulima.edu.pe; wneyraa@gmail.com

²Centro de Innovación Productiva y Transferencia Tecnológica del Cuero, Calzado e Industrias Conexas (CITEccal Lima) - ITP, Av. Caquetá 1300, Rímac, Lima, Perú; Imarrufo@itp.gob.pe

Received: 23.03.2020	Accepted: 30.06.2020	https://doi.org/10.24264/lfi.20.3.1
10001000.20.000.2020	//cccp/cd. 50.00.2020	

EFFICIENCY OF ELECTROCOAGULATION METHOD TO REDUCE COD, BOD AND TSS IN TANNERY INDUSTRY WASTEWATER: APPLICATION OF THE BOX-BEHNKEN DESIGN

ABSTRACT. This study intends to assess the removal efficiency of the chemical oxygen demand (COD), biochemical oxygen demand (BOD), and total suspended solids (TSS) from raw tannery wastewater using electrocoagulation by aluminum electrodes as well as to determine the effects of its main operating factors. Therefore, the response surface methodology was applied through an experimental Box–Behnken design by considering the current intensity (I), treatment time (T), and pH levels as the factors. In addition, the BOD, COD, and TSS removal percentages were considered to be the response variables. The results indicate that the treatment time, current intensity, and pH level were significant for COD and TSS, whereas only the treatment time was significant at a confidence level of p-value < 0.05 for BOD. For COD, the optimal operating conditions were I = 3 A, T = 24 min, and pH = 8.4; for BOD, the optimal operating conditions were I = 3 A, T = 24 min, and pH = 5.5; and for TSS, the optimal operating conditions were I = 2.7 A, T = 19 min, and pH = 7.4. Under these conditions, removal efficiencies of 56.8%, 69.2%, 99.9% were observed for COD, BOD, and TSS, respectively. The results suggest that electrocoagulation is an effective method for removing the parameters under study; therefore, it is a viable alternative for reducing the pollution issues caused by the tannery industry. KEY WORDS: tannery, electrocoagulation, aluminum electrodes, Box–Behnken design

EFICIENȚA METODEI DE ELECTROCOAGULARE PENTRU REDUCEREA CCO, CBO ȘI TSS DIN APELE UZATE ALE INDUSTRIEI DE PIELĂRIE: APLICAREA EXPERIMENTULUI BOX-BEHNKEN

REZUMAT. Acest studiu are obiectivul de a evalua eficiența reducerii consumului chimic de oxigen (CCO), consumului biochimic de oxigen (CBO) și a totalului materiilor solide în suspensie (TSS) din apele reziduale ale tăbăcăriilor, folosind electrocoagularea cu electrozi de aluminiu, precum și de a determina efectele principalilor factori de operare ai acestei metode. Prin urmare, metodologia suprafeței de răspuns a fost aplicată printr-un design experimental Box-Behnken, luând în considerare factori precum intensitatea curentului (I), timpul de tratament (T) și nivelul pH-ului. În plus, procentele de eliminare a CBO, CCO și TSS au fost considerate variabile de răspuns. Rezultatele indică faptul că timpul de tratament, intensitatea curentului și nivelul pH-ului au fost semnificative pentru CCO și TSS; pe de altă parte, doar timpul de tratament a fost semnificativ la un nivel de încredere al valorii p <0,05 pentru CBO. Pentru CCO, condițiile optime de operare au fost I = 3 A, T = 24 min și pH = 8,4; pentru CBO, condițiile optime de funcționare au fost I = 3 A, T = 24 min și pH = 5,5; iar pentru TSS, condițiile optime de funcționare au fost I = 2,7 A, T = 19 min și pH = 7,4. În aceste condiții, s-au observat valori ale eficiențe de reducere de 56,8%, 69,2%, 99,9% pentru CCO, CBO și, respectiv, TSS. Rezultatele sugerează că electrocoagularea este o metodă eficientă pentru reducerea parametrilor studiați; prin urmare, este o alternativă viabilă pentru reducerea problemelor de poluare cauzate de industria de pielărie. CUVINTE CHEIE: tăbăcărie, electrocoagulare, electrozi din aluminiu, experiment Box-Behnken

EFFICACITÉ DE LA MÉTHODE D'ÉLECTROCOAGULATION POUR RÉDUIRE LA DCO, LA DBO ET LES TSS DANS LES EAUX USÉES DE L'INDUSTRIE DU CUIR : APPLICATION DE LA CONCEPTION BOX-BEHNKEN

RÉSUMÉ. Cette étude vise à évaluer l'efficacité d'élimination de la demande chimique en oxygène (DCO), de la demande biochimique en oxygène (DBO) et du total des matières solides en suspension (TSS) des eaux usées de la tannerie en utilisant l'électrocoagulation par des électrodes en aluminium ainsi qu'à déterminer les effets de ses principaux facteurs de fonctionnement. Par conséquent, la méthodologie de la surface de réponse a été appliquée par le plan expérimental de Box-Behnken en considérant l'intensité du courant (I), le temps de traitement (T) et les niveaux de pH comme facteurs. De plus, les pourcentages d'élimination de la DBO, de la DCO et du TSS étaient considérés comme les variables de réponse. Les résultats indiquent que le temps de traitement, l'intensité du courant et le niveau de pH étaient significatifs pour la DCO et le TSS, alors que seul le temps de traitement était significatif à un niveau de confiance de valeur p <0,05 pour la DBO. Pour la DCO, les conditions de fonctionnement optimales étaient I = 3 A, T = 24 min et pH = 8,4 ; pour la DBO, les conditions de fonctionnement optimales étaient I = 3 A, T = 24 min et pH = 8,4 ; pour la DBO, les conditions de fonctionnement optimales étaient 0, les conditions, des rendements d'élimination de 56,8%, 69,2%, 99,9% ont été observés pour la DCO, la DBO et la TSS, respectivement. Les résultats suggèrent que l'électrocoagulation est une méthode efficace pour réduire les paramètres étudiés ; par conséquent, c'est une alternative viable pour réduire les problèmes de pollution causés par l'industrie du cuir.

MOTS-CLÉS : tannerie, électrocoagulation, électrodes en aluminium, conception Box-Behnken

217

^{*} Correspondence to: Edwar AGUILAR-ASCÓN, Universidad de Lima, Instituto de Investigación Científica (IDIC), Av. Javier Prado 4600, Surco, Lima, Perú; e-mail: eaguilaa@ulima.edu.pe

INTRODUCTION

The tannery industry is an important activity in the economic development of Peru and this is due to the diversity of articles that are generated from leather and the international demand of tanned skins until wet blue state (wet tanned skin). However, tanneries have been mainly characterized by the usage of low-technology and poor production practices that exacerbate the environmental problems associated with this industry by generating large volumes of highly polluted wastewater, mainly discharged in an untreated manner directly into rivers or sewage networks. According to the Peruvian national leather production data, between 45 and 50 m³ of effluents were produced for each ton of tanned leather in 2017, indicating the generation of approximately 30,000 m³ of effluents. The pollutant load of these effluents contains high amounts of chemical oxygen demand (COD), biochemical oxygen demand (BOD), and total suspended solids (TSS), sulfides, ammonium, chlorides, and heavy metals such as chromium. When high COD and BOD contents are reported in organic matter, water bodies lose a considerable amount of dissolved oxygen. This is harmful to aquatic organisms because it results in anaerobic activity that may release harmful gases. Therefore, the adoption of clean production and effluent treatment alternatives is of paramount importance. Estimates from the Center for Technological Innovation in Leather, Footwear, and Related Industries (CITEccal Lima) identified approximately 100 different tanneries in Lima. However, most of these tanneries have not yet implemented an effluent treatment system, which can ensure their compliance with the current environmental regulations, thus putting not only the environmental health but also the very existence of the industry at constant risk. Further, a possible solution to this issue may be the usage of electrocoagulation for treating raw tannery wastewater. In 2009, Ayhan Sengil et al. [1] applied electrocoagulation through steel and aluminum electrodes, achieving COD removal rates of 68%. In another study, Varank et al. [2] reported COD and TSS removal efficiencies of 82.2% and 85.5% when using aluminum electrodes and 67.4% and 86.2% when using steel electrodes, respectively, in 2014. Deghlesa *et al.* [3] also reported an optimal COD removal efficiency of 64.4% using aluminum electrodes. In 2017, Ufuk Durmaz *et al.* [4] determined the optimum operating values for COD and TSS removal through aluminum electrodes to be 18.9 mA/cm², 20 min of electrolysis time, and a pH level of 6.

Our study focuses on assessing the efficiency of the electrocoagulation process for removing the pollutants generated by the tannery industry expressed as BOD, COD, and TSS and on optimizing the process through the Box–Behnken (BBD) response surface methodology. Electrocoagulation offers many advantages over conventional treatments. In this process it is not necessary to add chemicals to the water, its reactors are more compact and simpler, and it has a high efficiency in the removal of various contaminants [5, 6]. In addition, as with any technology, it has some disadvantages, such as the periodic replacement of electrodes, the presence of high concentrations of aluminum and iron in the sewage sludge, and a high cost in places where there is no access to electrical energy [7]. Electrocoagulation is an electrochemical process in which metal plates, known as electrodes, are arranged in pairs, with one of the electrodes acting as the anode and the other acting as the cathode. Further, the cathode is oxidized, and the anode is reduced, generating hydroxide complexes acting as coagulants that allow the agglomeration of pollutants. Most of these agglomerates rise to the surface because of the fact that the hydrogen microbubbles perform a flotation process, whereas the rest are deposited in the bottom part of the water body [8]. Therefore, several types of electrodes, such as aluminum, iron, stainless steel, and platinum, have been tested [9]. In this study, we used aluminum electrodes as both the anode and the cathode, where reactions 1, 2 and 3 are generated [10].

At the anode:

$$Al \rightarrow Al^{3+} + 3e$$
 (1)
At the cathode:

$$3H_2O + 3e \rightarrow \frac{3}{2}H_2(g) + 3OH^-$$
 (2)
In the solution:

EFFICIENCY OF ELECTROCOAGULATION METHOD TO REDUCE COD, BOD AND TSS IN TANNERY INDUSTRY WASTEWATER: APPLICATION OF THE BOX–BEHNKEN DESIGN

(3)

 $Al^{3+}(aq)+3H_2O \rightarrow Al(OH)_3+3H^+(aq)$

EXPERIMENTAL

Materials and Methods

Tannery Wastewater

Water was collected from the pilot treatment plant at the Center for Technological Innovation in Leather, Footwear, and Related Industries (CITEccal), which generates industrial effluents from its tanning processes, to recreate the actual treatment conditions. This type of water contains high amounts of organic matter, pollutants and exhibits high conductivity because of the low-technological tanning processes used by the industry. Table 1 displays the values obtained from the initial effluent characterization. Table 1: Physicochemical Effluent Analysis

Parameter	Value
COD (mg/L)	4162.3
BOD (mg/L)	1825
TSS (mg/L)	1600
Conductivity (μ S/cm)	10560
рН	8.5
Turbidity (NTU)	1330
Chromium (mg/L)	114.56

Electrocoagulation Reactor

For these purposes, a Bacth type reactor with the following dimensions was used: length: 30 cm; width: 20 cm; and height: 25 cm. The total volume of the reactor was 15 liters, with the capacity to treat 12 liters of wastewater and a free volume of 3 liters for the accumulation of sludge. In total, we used 8 aluminum electrodes (4 as the anode and 4 as the cathode, each 10 cm wide and 10 cm long with a total area of 100 cm²). In addition, we used a series configuration, and the plates were spaced at 2 cm to reduce the demand of electric current owing to high water conductivity. Figure 1 displays a diagram of the reactor.



Figure 1. Electrocoagulation Reactor

Experimental Procedure

The experimental procedure proposes tests for three pH values of water (8.5, 7, and 5.5). In these three stages, different electric

current intensities were applied (1, 3, and 5 A), and samples were obtained at different times (8, 16, and 24 min). To measure the pH and conductivity, an Oakcton CON450 field meter was used. In addition, COD (SMEWW-APHA- AWWA-WEF Part 5220 D; 23rd), BOD (SMEWW-APHA-AWWA-WEF Part 5210 B; 23rd), and TSS (SMEWW-APHA-AWWA-WEF Part 2540-D; 23rd) were used to quantify the response variable. Finally, we used Equation 4 to determine the COD, BOD, and TSS removal percentages.

$$Y = \% R = \left(\frac{c_i - c_f}{c_i}\right) \times 100 \tag{4}$$

Here,

Y : Removal percentage of COD,BOD,and TSS C_i : Concentration of COD,BOD,and initial TSS C_i : Concentration COD,BOD,and final TSS

Box-Behnken Experimental Design

For this study, the response surface methodology with a Box–Behnken experimental

design was used using three factors, each factor with three levels, and 13 experiments by considering two experiments to denote the central values. The factors considered in the design were the electric current intensity (x_1) , treatment time (x_2) , and pH level (x_2) (see Table 2). To develop a response surface regression model, a complete quadratic model was applied (see Equation 5), where the experimental observations of the response variable were the COD, BOD, and TSS removal percentages. For the statistical analysis, the Statgraphics Centurión XVI software was used, which reported an analysis of variance (ANOVA) at a 95% confidence level. The polynomial model was evaluated by the value of the correlation coefficient R² and R² adj.

$$y_i = b_0 + \sum_{i=1}^{n} b_i x_i + \sum_{i=1}^{n} b_{ii} x_i^2 + \sum_{i=1}^{n-1} \sum_{j=i+1}^{n} b_{ij} x_i x_j$$

(5)

Factors	Levels			
x ₁ : Current Intensity (A)	1	2	3	
x ₂ : Time (min)	8	16	24	
x ₃ : pH Level	5.5	7	8.5	

RESULTS AND DISCUSSION

Effect of Current Intensity

Current intensity is one of the most critical parameters, which can significantly impact the effectiveness of the electrocoagulation process [8-11, 12]. As has been previously reported, as the intensity increases, the amount of anodic aluminum dissolution also increases, which leads to improved coagulation and pollutant removal [7]. For this study, we applied current intensities of 1, 2, and 3 A in a serial circuit to reduce energy consumption due to the high conductivity values presented by this type of wastewater. As the current intensity increases in Figures 2a, b; 4a, b; and 6a, b, it can be seen that the rate of removal of COD, BOD and TSS increases significantly. This is caused when a high current intensity is supplied to the reactor, generating a large number of monomeric and polymeric species according to Faraday's law, which reduces the amount of wastewater pollutants [8]. In Table 3 it can be seen that the highest removal values were obtained at 2 and 3 amps. With these current intensities a

removal of COD, BOD and TSS of 54%, 66% and 97%, respectively, was achieved. These results are not consistent with the results reported by Feng Jing-Wei et al. [13] in 2007, which indicate COD removal rates of more than 68% when using Al electrodes under current intensities of 0 to 1 A. The BOD removal results from our study also deviated from the results reported by Kongjao et al. [14], and Benhadji et al. [15], who reported efficiency values of 96% and 90%, respectively. However, these differences may be attributed to the different characteristics of the tested effluents. In 2014, Thirugnanasambandham et al. [8] reported values similar to the values reported herein, where an efficiency of 56.98% was achieved when applying a current density of 20 mA cm⁻² for 20 min. In addition, Espinoza et al. [16] obtained efficiencies of 50% and 65% for COD and TSS, respectively, when using a current density of 68 mA cm⁻². However, Ufuk Durmaz et al. [4] reported maximum removal efficiencies of 49% for COD and 42% for TSS when applying a current density of 22.7 mA/cm⁻², a pH level of 6, and a treatment time of 60 min. Tables 5 and 6 show the regression or slope coefficients of the model used. In the model for TSS, the

220

regression coefficient of the current intensity is positive, which indicates that the percentage of TSS removal (response variable) increases by an average of approximately 29,1667. In contrast, for BOD and COD the percentage of removal increases by approximately 19.3333 and 2.91667, respectively.

Effect of pH

The metal hydroxide precipitations are controlled by pH variations, which remove the pollutants while acting as coagulants [8]. To assess their impact on the treatment efficacy, the pH was changed from 5.5 to 8.5. The results from these variations are presented in Table 3 and Figures 2, 4, and 6. These results are very similar to the results obtained by Espinoza et al. [16], where optimal COD and TSS removal rates were reported for pH values of 6.5-8.0 and 6.5-8.5, respectively. Based on these results, a reduction of the pH to 5.5 improves the removal of organic matter (COD and BOD), whereas this does not result in a noticeable removal of TSS. In 2015, Deghlesa et al. [3] reported optimal COD removal values at a pH of 7. By considering that pH only had a minimal impact on the efficiencies, the modification of this parameter is not justified in practical applications, generating reagent consumption expenditure savings. In addition, Ufuk Durmaz et al. [4] reported optimal

efficiencies at a pH of 6 with a treatment time of 60 min.

Effect of Treatment Time

As known, the removal efficiency of pollutants increases as the electrolysis time increases due to the generation of metal ions and flocs [17-19]. The results for this parameter are shown in Table 3 and Figure 2, 4 and 6 which offer proof that the COD, BOD, and TSS removal rates increase as the treatment time progresses. These results are very similar to the ones reported by Tak et al. [20], which indicate an increase in efficiency after 10 to 20 min of treatment. In addition, Thirugnanasambandham et al. [8] reports that efficiencies may reach up to 72% after a treatment time of 20 to 60 min. Thus, determining the optimum treatment times becomes critical, especially when considering that very long treatment times generate high energy consumption and electrode wear [21], which would increase the treatment costs.

Results of the Box–Behnken Design

Table 3 presents the results obtained from the Box–Behnken factorial design for all 13 experiments with 2 central experiments using the pH, current intensity, and treatment time as independent variables.

		Factors			Removal	
Exp. No	Current (A)	Treatment Time (min)	рН	COD (%)	BOD (%)	TSS (%)
	X ₁	x ₂	\mathbf{x}_3	У ₁	y ₂	y ₃
1	1	16	5.5	36	57	74
2	2	8	5.5	43	60	79
3	2	24	5.5	54	66	85
4	3	16	5.5	51	63	89
5	1	8	7	24	43	76
6	1	24	7	30	45	89
7	3	8	7	36	48	94
8	3	24	7	46	54	97
9	1	16	8.5	22	57	81
10	2	8	8.5	23	59	86
11	2	24	8.5	36	63	95
12	3	16	8.5	35	63	96
13	2	16	7	37	46	96
14	2	16	7	38	47	97
15	2	16	7	36	46	96

Table 3: Box–Behnken Design for COD, BOD, and TSS removal

An empirical relation was observed between the COD, BOD, and TSS removal efficiency percentages, and the influence of the variables on the process can be obtained by correlating the experimental results with the response functions using the Statgraphics Centurion XVI software program.

In addition, ANOVA yielded a 95% confidence level (see Table 4) by comparing the variation sources against the Fisher's distribution (F-test) to validate the viability of the regression

model. Table 5 shows the regression coefficients for the second order response model. The response surface models are shown in Table 6. The coefficients of determination R² for COD (y_1), BOD (y_2), and TSS (y_3) are 98.5551%, 99.5823%, and 99.573%, respectively, which indicate a good model fit. Further, the results suggest that the treatment time, current intensity, and pH are significant for both COD and TSS, whereas only the treatment time was significant at a confidence level of p-value < 0.05 for BOD.

	Variation Source	Sum of	DF	MS	F-Test	P-Value
	variation source	Squares		1015	1 1030	i value
	$\mathbf{x}_{_1}$: Current Intensity (A)	392.0	1	392.0	108.9	0.0001
	$\mathbf{x}_2^{}$: Time (min)	200.0	1	200.0	55.56	0.0007
	x_3 : pH Level	578.0	1	578.0	160.56	0.0001
	x_1^2	33.2308	1	33.2308	9.23	0.0288
	x ₁ x ₂	4.0	1	4.0	1.11	0.3401
0	x ₁ x ₃	1.0	1	1.0	0.28	0.6207
8	x ² ₂	0.0	1	0.0	0.00	1.0000
	X ₂ X ₂	1.0	1	1.0	0.28	0.6207
	X_2^2	14.7692	1	14.7692	4.10	0.0987
	Total error	18.0	5	3.6		
	Total (corr.)	1245.73	14			
	$R^2 = 98.5551\%$, $Adj R^2 = 95.95$	542%				
	\mathbf{x}_1 : Current Intensity (A)	84.5	1	84.5	115.23	0.0001
	\mathbf{x}_2 : Time (min)	40.5	1	40.5	55.23	0.0007
	x ₃ : pH Level	2.0	1	2.0	2.73	0.1296
	\mathbf{x}_{1}^{2}	0.641026	1	0.641026	0.87	0.3927
	x ₁ X ₂	4.0	1	4.0	5.45	0.0668
Δ	X ₁ X ₂	0.0	1	0.0	0.00	1.0000
BO	X_2^2	9.25641	1	9.25641	12.62	0.0163
	X ₂ X ₂	1.0	1	1.0	1.36	0.2956
	X ₂ ²	732.333	1	732.333	998.64	0.0000
	Total error	3.66667	5	0.733333		
	Total (corr.)	877.733	14			
	$R^2 = 99.5823\%$, $Adj = 98.8$	303%				

Table 4: ANOVA Table

EFFICIENCY OF ELECTROCOAGULATION METHOD TO REDUCE COD, BOD AND TSS IN TANNERY INDUSTRY WASTEWATER: APPLICATION OF THE BOX–BEHNKEN DESIGN

	x_1 : Current Intensity (A)	392.0	1	392.0	500.43	0.0000
	x_2 : Time (min)	120,125	1	120,125	153.35	0.0001
	x_3 : pH Level	120,125	1	120,125	153.35	0.0001
	X_{1}^{2}	68.0064	1	68.0064	86.82	0.0002
	<i>X</i> ₁ <i>X</i> ₂	25.0	1	25.0	31.91	0.0004
SS	<i>X</i> ₁ <i>X</i> ₃	0.0	1	0.0	0.00	1.0000
Ĥ	x_{2}^{2}	34.1603	1	34.1603	43.61	0.0012
	$X_2 X_3$	2.25	1	2.25	2.87	0.1509
	x_{3}^{2}	183.083	1	183.083	233.72	0.0000
	Total error	3.91667	5	0.783333		
	Total (corr.)	917.333	14			
	R ² = 99.573%,	Adj = 98.8045%				

Table 5: Regression coefficients for the 2nd order response surface models

Torm	COD removal (%)		BOD removal (%)		SST removal (%)		Confidence intervals - 95.0 %		
lenn	Coefficient	P-value	Coefficient	P-value	Coefficient	P-value	Mean	Lower limit	Upper limit
Constant	88.2222	0.0192	348.37	0.0000	-129.185	0.0001	88.66	84.1559	93.0441
<i>X</i> ₁	19.3333	0.0273	2.91667	0.4193	29.1667	0.0001	2.0	1.58138	2.41862
<i>X</i> ₂	0.0833333	0.9194	-0.46575	0.1448	2.19271	0.0014	16.0	12.651	19.349
<i>X</i> ₃	-18.1111	0.0370	-87.2963	0.0000	45.3981	0.0000	7.0	6.37207	7.62793
x_{1}^{2}	-3.0	0.0288	-0.416667	0.5623	-4.29167	0.0002	4.533	2.83461	6.23206
$X_{1}X_{2}$	0.125	0.3401	0.125	0.0493	-0.3125	0.0016	32.0	22.2362	41.7638
$X_1 X_3$	-0.333333	0.6207	0	1.0000	0	1.0000	14.0	10.7811	17.2189
x_{2}^{2}	0	1.0000	0.0247396	0.0074	-0.047526	0.0010	290.113	181.415	398.852
$X_{2}X_{3}$	0.0416667	0.6207	-0.0416667	0.2532	0.0625	0.1219	112.0	86.2489	137.751
X_{3}^{2}	0.888889	0.0987	6.2596	0.0000	-3.12963	0.0000	50.2	41.3855	59.0145

 x_1 (current intensity, A), x_2 (time, min), x_3 (pH).

Table 6: Response surface model for COD, BOD and TSS removal (%)

Response	Quadratic polynomial model		P-value
COD removal (%)	$y_{1} = 88.2222 + 19.3333x_{1} + 0.0833333x_{2} - 18.1111x_{3} - 3.0x_{1}^{2} + 0.125x_{1}x_{2} - 0.33333x_{1}x_{3} + 0.0416667x_{2}x_{3} + 0.888889x_{3}^{2}$	98.5551	0.0005
BOD removal (%)	$y_2 = 348.37 + 2.91667x_1 - 0.46575x_2 - 87.2963x^3 - 0.416667x_1^2 + 0.125x_1x_2 + 0.0247396x_2^2 - 0.0416667x_2x_3 + 6.25926x_3^2$	99.5823	0.0000
TSS removal (%)	$y_{3} = -129.185 + 29.1667x_{1} + 2.19271x_{2} + 45.3981x_{3} - 4.29167x_{1}^{2} - 0.3125x_{1}x_{2} - 0.047526x_{2}^{2} + 0.0625x_{2}x_{3} - 3.12963x_{3}^{2}$	99.573	0.0000

The effects of the process variables are presented in Figures 2, 3, 4, 5, 6 and 7, which represent the three-dimensional (3D) and contour (2D) response surface plots. These plots use the mathematical models developed in Equations 6, 7, and 8, where the COD, BOD, and TSS removal percentage variations may be observed according to the variation of their current intensity (x_1) , treatment time (x_2) , and pH (x_3) . In addition, this allowed us to determine the optimum condition for each factor to maximize the COD, BOD, and TSS removal.



Figure 2. Three-dimensional (3D) response surface charts for COD removal percentages: 2a) current intensity and treatment time; 2b) current intensity and pH; and 2c) treatment time and pH



Figure 3. Two-dimensional (2D) response surface charts for COD removal percentages: 3a) current intensity and treatment time; 3b) current intensity and pH; and 3c) treatment time and pH

EFFICIENCY OF ELECTROCOAGULATION METHOD TO REDUCE COD, BOD AND TSS IN TANNERY INDUSTRY WASTEWATER: APPLICATION OF THE BOX–BEHNKEN DESIGN



Figure 4. Three-dimensional (3D) response surface charts for BOD removal percentages: 4a) current intensity and treatment time; 4b) current intensity and pH; and 4c) treatment time and pH



Figure 5. Two-dimensional (2D) response surface charts for BOD removal percentages: 5a) current intensity and treatment time; 5b) current intensity and pH; and 5c) treatment time and pH

E. AGUILAR-ASCÓN, L. MARRUFO-SALDAÑA, W. NEYRA-ASCÓN



Figure 6. Three-dimensional (3D) response surface charts for TSS removal percentages: 6a) current intensity and treatment time; 6b) current intensity and pH; and 6c) treatment time and pH



Figure 7. Two-dimensional (2D) response surface charts for TSS removal percentages: 7a) current intensity and treatment time; 7b) current intensity and pH; and 7c) treatment time and pH

CONCLUSIONS

This study proves that electrocoagulation by aluminum electrodes is effective for reducing COD, BOD, and TSS from tannery wastewater. As per the experimental design, all the factors (current intensity, treatment time, and pH) significantly affected COD and TSS, whereas only the treatment time significantly affected BOD. The correlation coefficient R² for COD, BOD, and TSS was 98.5551%, 99.5823%, and 99.573%, respectively, indicating a good model fit. For COD, the optimal operating conditions were established as I = 3A, T = 24 min, and pH = 8.4; for BOD, the optimal operating conditions were I = 3A, T = 24 min, and pH = 5.5; and for TSS, the optimal operating conditions were I = 2.7A, T = 19 min and pH = 7.4. Thus, optimum removal efficiencies of 56.8%, 69.2%, and 99.9% were achieved for COD, BOD, and TSS, respectively. Finally, it must also be emphasized that under actual treatment conditions, using reagents for changing pH would not be justified because the obtained efficiencies are very similar.

Acknowledgements

The authors thank the Institute of Scientific Research of the University of Lima for funding this research project and the Center for Productive Innovation and Technological Transfer of Leather and Footwear (CITEccal Lima) for their collaboration on the project.

REFERENCES

- Sengil, I.A., Kulac, S., Özacar, M., Treatment of tannery liming drum wastewater by electrocoagulation, *J Hazard Mater*, **2009**, 167, 940–946, https://doi.org/10.1016/j. jhazmat.2009.01.099.
- Varank, G., Erkan, H., Yazýcý, S., Demir, A., Engin, G., Electrocoagulation of tannery wastewater using monopolar electrodes: process optimization by response surface methodology, *Int J Environ Res*, **2014**, 8, 165–180, http://dx.doi.org/10.22059/ IJER.2014.706.
- Deghlesa, A., Kurt, U., Treatment of raw tannery wastewater by electrocoagulation technique: optimization of effective parameters using Taguchi method, *Desalination Water Treat*, **2015**, 57, 14798– 14809, https://doi.org/10.1080/19443994.2 015.1074622.
- Ufuk, D., Fehiman, C., Treatability of tannery wastewater by electrocoagulation process, *Period Eng Nat Sci*, **2015**, 5, 245–250, https://doi.org /10.21533/pen.v5i2.141.
- Kabdaşli, I., Arslan-Alaton, I., Ölmez-Hancı, T., Tünay, O., Electrocoagulation applications for industrial wastewaters: a critical review, *Environ Technol Rev*, **2012**, 1, 1, 2-45, https://doi.org/10.1080/21622515.2012.71 5390.
- Khaled, B., Wided, B., Béchir, H., Elimame, E., Mouna, L., Zied, T., Investigation of electrocoagulation reactor design

parameters effect on the removal of cadmium from synthetic and phosphate industrial wastewater, *Arab J Chem*, **2014**, https://doi.org/10.1016/j. arabjc.2014.12.012.

- Piña, M., Martin, A., Gonzáles, C., Prieto, F., Guevara, A., García, J., Revisión de variables de diseño y condiciones de operación en la electrocoagulación, *Rev Mex Ing Quím*, 2011, 10, 257–271, Recuperado de http://www. scielo.org.mx/scielo.php?script=sci_arttext& pid=S1665-27382011000200010.
- Thirugnanasambandham, K., Sivakumar, V., Removal of ecotoxicological matters from tannery wastewater using electrocoagulation reactor: modelling and optimization, *Desalination Water Treat*, **2014**, 57, 3871– 3880, https://doi.org/10.1080/19443994.20 14.989915.
- Elnenay, A.M.H., Nassef, E., Malash, G.F., Magid, M.H.A., Treatment of drilling fluids wastewater by electrocoagulation, *Egypt J Pet*, **2017**, 26, 203–208, https://doi. org/10.1016/j.ejpe.2016.03.005.
- Hamdan, S.S., El-Naas, M.H., Characterization of the removal of Chromium (VI) from groundwater by electrocoagulation, *J Ind Eng Chem*, **2014**, 20, 2775–2781, https://doi.org/10.1016/j. jiec.2013.11.006.
- Mollah, M., Morkovsky, P., Gomes, J., Kesmez, M., Parga, J., Cocke, D., Fundamentals, present and future perspectives of electrocoagulation, *J Hazard Mater*, **2004**, 114, 199–210, https://doi. org/10.1016/j.jhazmat.2004.08.009.
- Khandegar, V., Saroha, A.K., Electrocoagulation for the treatment of textile industry effluent- A review, *J Environ Manag*, **2013**, 128, 949–963, https://doi. org/10.1016/j.jenvman.2013.06.043.
- Feng, J., Sun, Y., Zheng, Z., Zhang, J., Li, S., Tian, Y., Treatment of tannery wastewater by electrocoagulation, *J Environ Sci*, **2007**, 19, 1409–1415, https://doi.org/10.1016/ s1001-0742(07)60230-7.
- 14. Kongjao, S., Damronglerd, S., Hunsom, M., Simultaneous removal of organic and

inorganic pollutants in tannery wastewater using electrocoagulation technique, *Kor J Chem Eng*, **2008**, 25, 703–709, https://doi. org/10.1007/s11814-008-0115-1.

- Benhadji, A., Ahmed, M.T., Maachi, R., Electrocoagulation and effect of cathode materials on the removal of pollutants from tannery wastewater of Rouïba, *Desalination*, **2011**, 277, 128–134, https://doi. org/10.1016/j.desal.2011.04.014.
- Espinoza-Quiñones, F.R., Fornari, M.M.T., Modenes, A.N., Palacio, S.M., Trigueros, D.E.G., Borba, F.H., Kroumov, A.D., Electrocoagulation efficiency of the tannery effluent treatment using aluminum electrodes, *Water Sci Technol*, **2009**, 60, 2173–2185, https://doi.org/10.2166/ wst.2009.518.
- Alaani, H., Hashem, S., Karabet, F., Electrochemical removal of hydrocortisone from aqueous environments using aluminum electrodes, *Orient J Chem*, **2018**, 34, 1, 203-213, http://dx.doi.org/10.13005/ ojc/340123.
- Alsalka, Y., Karabet, F., Hashem, S., Evaluation of electrochemical processes for the removal of several target aromatic hydrocarbons from petroleumcontaminated water, *J Environ Monit*, **2011**, 13, 605–613, https://doi.org/10.1039/ C0EM00450B.

- Mahmoud, M.S., Farah, J.Y., Farrag, T.E., Enhanced removal of Methylene Blue by electrocoagulation using iron electrodes, *Egypt J Pet*, **2013**, 22, 211–216, https://doi. org/10.1016/j.ejpe.2012.09.013.
- Tak, B.Y., Tak, B.S., Kim, Y.J., Park, Y.J., Yoon, Y.H., Min, G.H., Optimization of color and COD removal from livestock wastewater by electrocoagulation process: application of Box–Behnken design (BBD), *J Ind Eng Chem*, **2015**, 28, 307-315, https://doi. org/10.1016/j.jiec.2015.03.008.
- Kobya, M., Hiz, H., Senturk, E., Aydiner, C., Demirbas, E., Treatment of potato chips manufacturing wastewater by electrocoagulation, *Desalination*, **2006**, 190, 201–211, https://doi.org/ 10.1016/j. desal.2005.10.006.

© 2020 by the author(s). Published by INCDTP-ICPI, Bucharest, RO. This is an open access article distributed under the terms and conditions of the Creative Commons Attribution license (http:// creativecommons.org/licenses/by/4.0/).

228